

## RAJASTHAN ELECTRICITY REGULATORY COMMISSION

### NOTIFICATION

Jaipur, 19 January 2016

**No. RERC/Reg. No. 114** - In exercise of powers conferred by Section 57 & 58 read with Section 181 of the Electricity Act, 2003 and after previous publication, the Rajasthan Electricity Regulatory Commission hereby makes the following regulations, namely: -

#### 1. Short Title and Commencement

- (i) These regulations shall be called the 'Rajasthan Electricity Regulatory Commission (Transmission Licensee's Standards of Performance) (Second Amendment) Regulations, 2016';
- (ii) These Regulations shall be applicable to all Transmission Licensees.
- (iii) These Regulations shall come into force on the date of their publication in official gazette.

#### 2. Amendment in Regulation 6:

Sub-regulation (1), titled "Voltage Profile", under Regulation 6 shall be replaced by the following:

"(1) Voltage Profile:

Licencee shall make all possible efforts to ensure that the grid voltage remains within the following voltage levels at all EHV sub-stations of its Transmission System and on real time basis at SLDC. Voltage profile at each interconnection point shall be maintained as under:

| Nominal System Voltage (kV rms) | Grid Voltage (kV rms) |         |
|---------------------------------|-----------------------|---------|
|                                 | Maximum               | Minimum |
| 765                             | 800                   | 728     |
| 400                             | 420                   | 380     |
| 220                             | 245                   | 198     |
| 132                             | 145                   | 122     |
| 33                              | 36                    | 30      |
| 11                              | 12                    | 10      |

"

By order of the Commission

(G. K. Sharma)  
Secretary