

Future Ready Networks

Empowering our customers in their energy future

Tom Langstaff, Manager, Networks Planning


13 March 2019



Integrating DER

Distributed Energy Resources challenge the traditional network hierarchy,


a hierarchy designed to supply energy to its customers not take energy from them.




Growth in the number of solar customers will accelerate...with EV and Battery on the rise



Solar forecast comparison
inc. Industrial and Comm.




Customers voltage will now rise not just fall



Actual customer experiences


A distribution transformer over four average (non peak) days



Rooftop solar PV system sizes are increasing rapidly




Size of solar PV systems installed - 2011v. 2017



Rooftop solar generation does not materially reduce network peak




Impact of rooftop solar PV on network demand



Solar customers (as a group) have a higher peak demand than non-solar




Solar customers v. non-solar customers on a hot day



Solar customers (as a group) typically export during the day




Average residential demand profiles on Christmas Day 2017




and we are at the cross roads for reverse flows..



Hampton park minimum demand trend




we expect large reverse flows of 20 MW by 2025




we expect reverse flows across our network



AusNet Services Zone Substation minimum demands



Customers in rural areas will be the most effected




Integrated HV-LV Analysis of PV-rich Distribution Networks: An AusNet Case Study

1. Introduction

The “HV-LV Analysis of Mini Grid Clusters” project was carried out to investigate the impacts of clusters of new PV-ready LV networks (100% PV) on an existing HV feeder.

2. HV – LV Network Modelling



- 22kV Feeder
- 79 Dist. Tx.
- 6.5MW Peak Demand




- 12 x 500kVA Tx. (22kV / 0.412kV)
- 4c / 240 sq.mm cables
- ~1400 Houses
- 100% PV – 4 kWp

Integrated HV-LV analysis, smart demand and generation data, time-series three-phase analysis.


3. Impact Assessment

Impact assessment carried out for two cases, using data of a summer day with minimum midday demand.

Current (Minimal PV Penetration) HV Feeder State:



Future (50% PV Penetration) HV Feeder State:



4. Potential Solutions

Solutions Assessed	Line Utilization	Voltage Problems	Curtailment
No Solution	142%	9.3%	1.3%
Change OLTC Settings	147%	0%	0.2%
Change Volt-Watt Settings	98.4%	0%	55.9%
Enable Volt-Var Function	143%	1.15%	0.6%
PV Export Limit	99.5%	0%	57.3%
Grid-scale Storage	86.3%	0%	0%

4. Conclusions on Successful Solutions

- **Change Volt-Watt Settings:** High curtailment, requires extensive tuning, unfair curtailment depending on location in the network, uses existing assets.
- **PV export limit:** High curtailment, requires minimal tuning, uses existing assets.
- **Grid-scale Storage:** No curtailment, requires new assets (expensive).

Thanks for your time

Tom Langstaff

Manager Networks Planning

AusNet Services

Level 30, 2 Southbank Boulevard

Southbank Victoria 3006 Australia

Tel +61 3 9695 6859 Mobile +61 (0) 438 338 488

tom.langstaff@ausnetservices.com.au

www.ausnetservices.com.au

